

工事名 町民交流センター照明器具改修工事

建築積算数量調書

[illegible]

集計表一2

積算(建築)

直接仮設		仕上計算										NO.	1					
仕 上		計算				数量		仕 上		計算				数量				
内部改修								内部足場										
足場設置部 床養生		W	D	箇所	=			枠組棚足場	H=8.1									
ステージA		20.00	×	5.00	×	1.00	= 100.00	1,562.91	m2	ステージA	20.00	×	5.00	×	1.00	= 100.00	100.00	m2
アリーナ		40.00	×	33.50	×	1.00	= 1340.00			くさび緊結式足場	平均 H=12.15							
展示ホール吹き抜け		3.92	×	2.50	×	1.00	= 9.80			アリーナ	38.00	×	31.50	×	1.00	= 1197.00	1197.00	m2
展示ホール吹き抜け		22.46	×	3.50	×	1.00	= 78.61											
吹き抜け部 階段		5.00	×	6.90	×	1.00	= 34.50			枠組棚足場	H=8.0							
小ホール吹き抜け		14.70	×	15.85	×	1.00	=			展示ホール吹き抜け	3.92	×	2.50	×	1.00	= 9.80	88.41	m2
										展示ホール吹き抜け	22.46	×	3.50	×	1.00	= 78.61		
清掃片付け																		
延床面積3F	1F					= 2818.29	3,142.45	m2										
	2F					= 324.16				枠組棚足場	H=8.9							
▲非改修室										小ホール吹き抜け	10.70	×	13.85	×	1.00	=	0.00	m2
無し		×	×		= 0.00					階段室足場	H=8.0							
								※	吹き抜け部 階段	5.00	×	6.90	×	1.00	= 34.50	34.50	m2	
外部改修																		
清掃片付け										天井平均高さ算定								
玄関ホール		10.00	×	12.00	×	1.00	= 120.00	120.00	m2	アリーナ 勾配屋根全体面積	40.00	×	33.50	×	1.00	= 1340.00	m2	
										H=10～14.3m(10.00	+	14.30)÷	2.00	= 12.15	m	平均天井高
										</								

積算(建築)

[illegible]

[illegible]